

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING NO: 6911-0476:112

Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Harrington Signal Inc., 2519 4th Ave, Moline, IL 61265  
Contact: Andrew Keller (309) 762-0731

DESIGN: Models HS 101-RMT emergency voice evacuation, relocation, and paging system. Refer to listee's data sheet for additional detailed product description and operational considerations.  
System components:

101-CE-X	Common Equipment Board
101-SPK	Speaker Module
101-STRB	Strobe Module
101-CHS	Common Equipment Chassis
101-PS/PS-MAIN/PS-AUX	Power Supply
101-AMP	Amplifier Driver
MM-1	Pre-Recorded Message Module
CAB-F	Enclosure

RATING: Primary: 120 VAC, 2A per power supply assembly  
Secondary: 24 VDC, 6.5 - 26 Ah capacity

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use as a stand alone audio unit or with separately listed and electrically compatible fire alarm control unit.

XLF: 6911-1393:104

07-24-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager